

section II

# ACTIVITIES IN WP3.3

**DTU Electrical Engineering**  
Centre for Electric Technology



# Integration with EnergyPlan

- EnergyPlan addresses some grid requirements
- Required "stabilization share" (connected large synchronous generation):
  - Estimated 30% according to experience from system operators
  - CEESA calculates with 0%
  - *Theoretical minimum* unknown
- stabilizing contribution from renewable energies
  - Possible, to be investigated...

DTU Electrical Engineering  
Centre for Electric Technology

**Electric grid stabilisation requirements:**

Minimum grid stabilisation production share	<input type="text" value="0,3"/>
Stabilisation share of CHP2	<input type="text" value="0"/>
Minimum CHP in gr. 3:	<input type="text" value="300"/>
Heat Pump Maximum load:	<input type="text" value="0,5"/>

**Electricity production from Renewable**

	Renewable Energy Source	Capacity MW	Stabilisation	Distribution profile
<input type="button" value="Change"/>	Wind	<input type="text" value="1000"/>	<input type="text" value="0"/>	<input type="button" value="Change"/> Hour_win
<input type="button" value="Change"/>	Photo Voltaic	<input type="text" value="500"/>	<input type="text" value="0"/>	<input type="button" value="Change"/> Hour_win



# Discussion toward including operation-requirements in EnergyPLAN

- I. Requirements for system "stability" / "Operational Requirements".
  - a) For Interconnected Areas (inertia&primary control shared)  
OPTION: trading of ancillary services.
  - b) For islanded systems
- II. Generalized/relevant device-properties  
Energy storage, response time, availability, "distributedness", ...
- III. "Services" to be recognized by EnergyPLAN  
Active Power Reserves, Non-active power requirements (voltage control etc.) (?)
- IV. List of devices(now and future) modeled in EnergyPLAN, their properties and mapping to the respective "services".

# Stability Requirements for EnergyPLAN

- discussing extension to Energyplan:
  - Revision of “stability” requirements
  - to include capacity reserve for intra-hour variation
  - Document *different requirements* for islands and interconnected systems
- \*ideally\* should follow from WP3.1 and 3.2, but does require additional simulation studies.

# What is in the scenarios? (IDA 2030 / 2050)

## A. Central Generation

- Replace future power [...] by fuel cell CHP plants, equal to 35-40 per cent of total power plants in 2030, (individual house heating → district heating CHP)
- Introduce 450 MWe large heat pumps
- *Replace all CHP and power plants by fuel cell-based or biogas or biomass gasification*

## B. Renewable Electricity (uncontrolled)

- Increase wind power  
3000 MW to 6000 MW in 2030  
onshore@3000MW, 3000MW offshore)
- 500 MW wave; 700 MW PV
- *Increase wave power to 1000 MW*
- *Wind power (all offshore)*  
*IDA2050: 7000MW //*  
*IDA2050Biomass: 3000MW //*  
*IDA2050Wind: 12000MW*

## C. (controllable) Distributed Generation

- Replace natural gas boilers by microCHP, ~10 per cent of house heating
- *Convert micro CHP systems from natural gas to hydrogen*

## D. Electricity Demand Reduction

- ... by 50 per cent in private households
- ...by 30 per cent in industry

## E. (controllable) Demand flexibility

- Flexible electricity demand in order to integrate wind power and CHP better in the energy system. (quantification?)
- *3TWh of industrial heat from heat pumps*

## F. Transportation – V2G

- 20 per cent of fuel for road transportation by electricity (and 20 per cent by biofuels)
- *Stabilise the transportation demand at the 2030 level*

# Mapping to Electricity perspective

- 1. Generation Units                      ← *more renewables, less inertia?*
- 2. Grid Design                              ← *transmission network, components?*
- 3. Balancing Control                      ← *Intermittency*
  - 1. Controllability issues
  - 2. Balancing resources (time scales/ volume)
- 4. Network Control (Operational stability)      ← *Changing flows*
  - 1. Voltage Control
  - 2. Distributed inputs
  - 3. Reactive flows and congestion management

## 5. (Protection Systems)

Measures Tech. Areas	A.	B.	C.	D.	E.	F.	WP3.1	WP3.2
	Central Generation	renewable Electricity	Distributed Generation	Demand reduction	Demand Flexibility	Transportation		
I.	X	x		-	-	-	?	?
i.	X	x	x	?				
II.	X	X		x	X	X	X	X
i.	x	X		?	X	X	X	X
ii.		X	X		X	X		X
III.		x	X	-	X	?	X	x?
i.		x			X		?	x
ii.			X		X		X	x
iii.	X				x	x	x	
IV.	?	?		-	?		X?	?

X – major, x – minor, ? – unclear, - – none

# Initial comments / Apparent challenges

- The fundamental (frequency-forming) unit of power systems is the *synchronous generator*.  
Introduction of *fuel-cell CHP plants* means to remove stabilizing system inertia.  
→ complete replacement of CHP plants by fuel cells seems most radical system change
- All measures are stated with reference to Ref2030 scenario\*  
→ scenario descriptions are only relative changes.  
A “business as usual” power system model does not exist.  
Further, a power system for the whole of Denmark is not available for us, neither tractable.